

**Arkansas State Mandated Inspections
Public Schools**

03/26/2020

RESPONSIBLE PARTY	SYSTEM	FREQUENCY	CODE SECTION OR REGULATION
SCHOOL DISTRICT	Fire Extinguishers	Monthly	AFPC, Vol. 1, Section 906.2 & NFPA 10
	Asbestos Program	6 Month	US EPA AHERA Plan
		3 Year	US EPA AHERA Plan
FIRE MARSHAL	Fire Safety	6 Month	A.C.A. § 6-21-106
	Fire Alarm	Annual	AFPC, Vol. 1, Table 901.6.1, & NFPA 72
	Fire Sprinkler	Annual	AFPC, Vol. 1, Table 901.6.1, & NFPA 25
	Fire Extinguisher	Annual	AFPC, Vol. 1, Section 906.2 & NFPA 10
		6 Year	AFPC, Vol. 1, Section 906.2 & NFPA 10
	Kitchen Suppression – Wet Chemical	6 Month	AFPC, Vol. 1, Section 904.5-904.5.1 & NFPA 17A
	Kitchen Suppression – Dry Chemical	6 Month	AFPC, Vol. 1, Section 904.6-904.6.1 & NFPA 17
HEALTH DEPARTMENT	Natural Gas	Annual	A.C.A. 17-38-201(a)(6)(A)
	Food Service	6 Months	Food Establishment Regulations, Section 8-401.10 page 141
	Back-flow Prevention	Annual	Arkansas Plumbing Code (2006) 312.9
LABOR DEPARTMENT	Hot Water Boilers	HP - Annual	A.C.A. § 20-23-203
		LP External - Annual	
		LP Internal - 3 Year	
		Unfired Pressure Vessel - 2 Year	
	Elevator	Annual	A.C.A. § 20-24-112(a)(3)(A)(i)
ARKANSAS DEPARTMENT OF ENVIRONMENTAL	Sewage Treatment	District staff check daily - 5 Years	ADEQ policy – NPDES 40-1-D-122.46
	Fuel & Oil Tanks	3 Year	APC&EC Regulation Title 40-D, 280.43 & 280.44